



INSTALL SEWER SERVICE LINE
 1/4" PER FOOT MIN.
 1/2" PER FOOT MAX.

NOTES:

1. SEWER SERVICES TO BE CONSTRUCTED IN ACCORDANCE WITH SECTION 02730 OF THE MONTANA PUBLIC WORKS STANDARD SPECIFICATIONS, LATEST EDITION, AND UNIFORM PLUMBING CODE.
2. MIN. DEPTH OF COVER SHALL BE 5' AT END OF SERVICE STUB.
2. DETECTABLE WARNING TAPE SHALL BE INSTALLED ABOVE ALL SERVICES

SEWER SERVICE DETAIL

NO SCALE

	 <p>TD&H Engineering</p> <p>406.586.0277 • tdhengineering.com</p> <p>234 E. BABCOCK ST., SUITE 3 • BOZEMAN, MONTANA 59715</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="font-size: small;">DRAWN BY:</td><td> </td></tr> <tr><td style="font-size: small;">DESIGNED BY:</td><td> </td></tr> <tr><td style="font-size: small;">QUALITY CHECK:</td><td> </td></tr> <tr><td style="font-size: small;">DATE:</td><td> </td></tr> <tr><td style="font-size: small;">JOB NO.</td><td> </td></tr> <tr><td style="font-size: small;">CAD NO.</td><td>SWR SVC DETAIL</td></tr> </table>	DRAWN BY:		DESIGNED BY:		QUALITY CHECK:		DATE:		JOB NO.		CAD NO.	SWR SVC DETAIL
DRAWN BY:														
DESIGNED BY:														
QUALITY CHECK:														
DATE:														
JOB NO.														
CAD NO.	SWR SVC DETAIL													